



VĮ STATYBOS PRODUKCIJOS SERTIFIKAVIMO CENTRAS
Linkmenų str. 28, LT-08217 Vilnius, Lithuania
Notified body No. 1397



LIETUVOS
NACIONALINIS
AKREDITACIJOS
BIURAS

Waste Water Treatment Plant Laboratory

BANDYMAI
ISO/IEC 17025

Nr. LA. 01.103

TEST REPORT No. 1397-CPR-064/A_s
According to EN 12566-1:2000 and EN 12566-1:2000/A1:2003 Annex A.
(Nominal capacity test)

2014-04-15

1. CLIENT: KLAASPLAST OÜ, adress Kuke talu, Kolu küla Kose vald Harjumaa, 75121 Estonia Reg. Nr. 11862070, contract No. NVI-49_2014 at 2014-03-12.
2. MANUFACTURER: KLAASPLAST OÜ, adress Kuke talu, Kolu küla Kose vald Harjumaa, 75121 Estonia Reg. Nr. 11862070.
3. SAMPLE: Septic tank S2. Material – glass reinforced plastic (GRP).
4. SAMPLE DELIVERY DATE: 2014-03-12.
5. TESTING LOCATION, ADDRESS AND DATE:
 - Wastewater Treatment Plant Laboratory Maišiagala, Vilnius district.
 - The date of test 2014-04-04.
6. SAMPLING: Sampling made by the Client, sampling report No. 049-Klaastplast.
7. IDENTIFICATION OF THE METHOD USED:
The test made according to EN 12566-1:2000 and EN 12566-1:2000/A1:2003 *Small wastewater treatment systems for up to 50 PT – Part 1: Septic tanks. Clause 5.4 and Annex A Clause A1. Nominal capacity test.*
8. TEST SPECIFICATIONS:
The septic tank was filled to the outlet level with clean water. The volume of water recorded in litres with an accuracy of <1%.
Ambient temperature during the test: 8 °C
Water temperature: 10,5 °C
9. TEST RESULTS: 1,928 m³ (1928 litres).

The test results relate only to the items tested.

Head of laboratory

Arnas Danila

Director

Robertas Encius

