



STATYBOS PRODUKCIJOS
SERTIFIKAVIMO CENTRAS

PERFORMANCE RESULTS

KLAASPLAST OÜ

Kuke talu, Kolu küla Kose vald Harjumaa, 75121 Estonia

EN 12566-3:2005+A1:2009

EN 12566-1:2000 and EN 12566-1:2000/A1:2003

“Small wastewater treatment systems for up to 50 PT”

Small wastewater treatment system

S4

Material	glass reinforced plastic (GRP)
Watertightness (water test)	pass
Crashing resistance (pit test, conditions: WET 0,95 m)	pass

Performance tested by:

SPSC - Statybos produkcijos sertifikavimo centras

Linkmenu str. 28

LT-08217 Vilnius

Lithuania

Notified Body number: 1397

Director Robertas Encius

April 2014

Reg. Nr. 10_2014

Statybos produkcijos sertifikavimo centras www.spssc.lt

Statybos produkcijos sertifikavimo centras www.spssc.lt